

5.6.2015

Finnish comments on EN 14471:2013+A1 Chimneys - System chimneys with plastic flue liners - Requirements and test methods

We refer to the email of Manfred Fuchs dated 2.6.2015. The objection of Finland was based on information from TC 166, which had noticed severe problems in EN 14471:2013. TC 166 did not want to cite EN 14471:2013 in the OJ.

TC 166 has quickly drafted an amendment where these problems have been resolved.

Finland voted positively concerning this amendment. Finland had only two editorial remarks which are the followings:

- Mod 4.3 "The Amendment proposes to move the N2 remark to a note. This will decrease the level of importance of the remark, with the clear risk that more leakage could be accepted." it is better to leave as it was.
- Mod 4.4 "The Amendment proposes to move the G remark to a note. This will decrease the level of importance of the remark, with the clear risk that in the future plastic could be used for application that generate sootfire. " It is better to leave as it was.

With best regards,



Teppo Lehtinen

Head of the Finnish Delegation to SCC

